



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

CERTIFICATE OF CONSTANCY OF PERFORMANCE
1783-CPR-585

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation-CPR), this certificate applies to the construction product

Scope is given attached.

placed on the market under the name or trade mark of

KONTROL CİHAZLARI SANAYİ VE TİCARET LTD. ŞTİ.
Marmara Sanayi Sitesi G Blok No:8-10-15-16-17-12-13-14-23 İkitelli Küçükçekmece-
İSTANBUL/TÜRKİYE

and produced in the manufacturing plant

KONTROL CİHAZLARI SANAYİ VE TİCARET LTD. ŞTİ.
Marmara Sanayi Sitesi G Blok No:8-10-15-16-17-12-13-14-23 İkitelli Küçükçekmece,
İSTANBUL

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 331:1998, EN 331:1998/A1:2010,

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 12.05.2017 and revised on 15.04.2021 due to content correction ,and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, Rev.2, 15.04.2021



Dr. Fırat Hacıoğlu
Deputy Director of Directives



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

ANNEX OF CERTIFICATE OF CONSTANCY OF PERFORMANCE

Manually operated ball valves and closed bottom taper plug valves for gas installations for buildings

Tip / Type	520-15	520-20	520-25	520-32	520-40	520-50
Basınç Sınıfı / <i>Pressure Class</i>	MOP 0,5					
Çalışma Basınç Aralığı / Operating <i>Pressure Range</i>	0-0,5x10 ⁵ Pa					
Anma Boyutu / <i>Nominal Size</i>	15	20	25	32	40	50
Gaz Ailesi / Gas <i>Family</i>	1-2-3					
Sıcaklık Sınıfı / <i>Temperature Class</i>	-20°C					
Çalışma Sıcaklık Aralığı / Operating <i>Temperature Range</i>	Between -20°C and 60°C					
Yangına Tepki Sınıfı / Reaction to <i>fire class</i>	Class A1					
Yüksek Sıcaklığa Direnç / Resistance <i>to high temperature</i>	Pass					
Malzeme / Material	Gövde <i>/ Body</i>	CW617N				
	Küre <i>/ Ball</i>	CW617N				
	Kol / Lever	HRP Sac				
	Somun <i>/ Nut</i>	SAE1006				
	Küre Sızdırmazlığı <i>/ Ball Seal</i>	PTFE				
Bağlantı / <i>Connections</i>	Threaded connections					
Kumanda / <i>Operation</i>	Manually operated					



Annex 06A783-CPR-585 numbered Constancy of Performance of Certificate. Rev02, 15.04.2021

Page2/2